

'Potencia' (Power) Options for Single-Phase and 3-Phase Supply Contracts

Power Contracted / 'Potencia Contratada'				Maximum Current
Single Phase Contracts		3-Phase Contracts		
setup after 2005 nominal supply voltage of 230V Kilowatts	setup before 2005 nominal supply voltage of 220V Kilowatts	setup after 2005 nominal supply voltage of 400V Kilowatts	setup before 2005 nominal supply voltage of 380V Kilowatts	limited by Smart Meter (where fitted) or ICP in fusebox (if fitted) Amps
-	-	1.039	987	1,5
-	-	2.078	1.975	3
-	-	2.425	2.304	3,5
1.150	1.100	3.464	3.291	5
-	-	5.196	4.936	7,5
2.300	2.200	6.928	6.582	10
3.450	3.300	10.392	9.873	15
4.600	4.400	13.856	13.164	20
5.750	5.500	17.321	16.454	25
6.900	6.600	20.785	19.745	30
8.050	7.700	24.249	23.036	35
9.200	8.800	27.713	26.327	40
10.350	9.900	31.177	29.618	45
11.500	11.000	34.641	32.909	50
-	-	43.648	41.465	63